APPLICATION No.: #31828	TAP CLEARED				
LOCATION: S .S. Howard Ave. E x River Rd.	DATE	BEF.	AFT.	REMARKS	
OWNER: Coyne Laundry					
MEASURES: 8" Ductile pipe Feb. 18 & 22, 1994					
W x E line River Rd. 29.5 ft. N x S line Howard Ave. 16.0 ft.					
F <sub>IRE</sub> S <sub>UPPLY</sub>					
Feb. 13, 1996 Replaced broken gate box, could not get on gate to s	hut off.				
N from S Line Howard Ave 13.4 S from Domestic Serv gate valve 5.4 W from E line River Rd 7.3 N from N Line Building 16.0 W from W Line Building 90.0 W Domestic Serv Gate Valve 7.0					
01/12/13 City Crew installed new gate valve for fire supply.  Stock: 2 - 8" #441, 1 - 8" Gate Valve, 1 - 1" Tap, 2.5' - 8" Ductile Pipe. 1 - Gate Box; J. Medeiros					

METER HISTORY									CHARGE OUTS		
DATE	SET	SIZE	MAKE	NUMBER	READING	TEST		TEST RE		REMARKS	
	OUT										
-											
-											
			4		•	,					