

APPLICATION No.: 31832

LOCATION: 482 Cottage St

TAP CLEARED

OWNER: _____

31-313

MEASURES:

May 5, 1994

S x S line Parker St 112.0'

W x E line Cottage St 7.0'

N x S line house 1.9'

1" COPPER SERVICE

3/16/2020: Lead service line replacement program

phase 1, Contractor P. Gioioso & Sons

TYPE CU, Diameter inch 1, Water Pressure 50

Distance from main to curb stop 22.2'

Distance curb stop to meter 18.5'

Distance from curb face to curb stop 1.0'

Depth of service 4.0'

Total length of new pipe installed 27'

Curb stop replaced YES: Size 1"

Corporation replaced YES: Size 1"

Ball Valve furnished NO: Size 0.75'

Remarks: 1- 3/4" union installed where shown

DATE

BEF.

AFT.

REMARKS

[illegible]