

#259

APPLICATION No.: 32640

TAP CLEARED

LOCATION: N.S. Sam Barnet Blvd W x town line

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

6" DOM 2021

N x N line Sam Barnet Blvd 60.0'

E x W line bldg 5.0'

main X north 67.0'

pipe inside prop 227.0'

S x S line bldg 15.0'

main X north to box 125.0'

9-23-21: Shut down fire supply service, for private
property work, & turned back on. Contractor: Farland Corp
Inspector P. Reynolds

9-30-2021: Temporary fire supply inspection,
Private Prop. Farland Corp contractor; Inspector
P. Reynolds.domestic 32639

9-29-21: Inspection

12-8-2021: Inspection

Fire supply #34147

1-3-2022: Pressure Test Length of main 220' number of
hydrants 0, Number of gate valves 1, number of services
1, test pressure 150 Leakage 0, Test conducted by
Winwater/ City of Nb Inspector P. Reynolds

METER HISTORY

[illegible]

CHARGE OUTS

#259

APPLICATION No.: 32640

TAP CLEARED

LOCATION: S. Barnet Blvd

OWNER:

31-313

MEASURES: 6"

fire supply

N x N line

Samuel Barnet Blvd

60.0'

E x W line

build

5.0'

N x N line

sam bar blvd

60.0'

main x North

67.0'

S x S line

buil

15.0'

main x N to box

125.0'

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS