

✓

APPLICATION No.: #32647		TAP CLEARED			
LOCATION:	200 State St.	DATE	BEF.	AFT.	REMARKS
OWNER:	Hallkeen State Limited Partnership				
MEASURES:	4" C.L.C.I. April 23, 2002				
F I R E S U P P L Y					
Measures of 6" Tapping Valve - Fire Supply					
S x S line Linden St. 191.5 ft.					
E x W line State St. 16.1 ft.					
N x N line Bldg. "C" 8.0 ft.					
W x W line Bldg. "C" 27.0 ft.					
East Coast Water Works, Wareham, Ma. installed:					
20" x 6" Mueller Tapping Sleeve					
6" Mueller Tapping Gate Valve					
6" x 4" Reducer (W x E line State St. 7.6 ft.)					
12.3 ft. pc - 4" DI pipe to a 4" x 4" Tee (heading North)					
1.0 ft. pc of 4" DI pipe to a 4" gate valve					
14.5 ft. into cellar of Bldg. "B"					
24.7 ft. of 4" DI pipe to a second 4" x 4" x 4" Tee					
South from tee: 2.5 ft. pc of 4" DI pipe to					
a 4" Gate Valve					
10 ft. pc of 4" DI pipe into cellar of					
Bldg. "C"					
Supplies Fire Supply to:					
#32644					
#32645					
#32646					

[illegible]

CHARGE OUTS

[illegible]