

APPLICATION No.: 3272

LOCATION: 12 Grape St

OWNER:

31-313

MEASURES: Dec 4, 1878

W X Oak St

112.1 ft

N X S Line Grape St

6.7 ft

E X W Line House

3.0 ft

1" Copper Service

07/23/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 75

Distance from main to curb stop (ft) 8.5

Distance from curb stop to meter (ft) 15.4

Distance from curb face to curb stop (ft) 2.3

Depth of service (ft) 4.0

Total length of new pipe installed (ft) 23.9

Curb stop replaced: yes size 1"

Corporation replaced: yes size 1"

Ball valve furnished: yes size 1"

## TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]