

REPLACES SERVICE # 13847

APPLICATION No.: 32944

LOCATION: 9 Irvington Ct

OWNER:

31-313

MEASURES: 1" Copper 8/4/2004

Princeton St	Main to curb stop	114.0
N from N line	Princeton St	82.2
E from W line	Irvington Ct	4.0
S from N line	House	24.0
N from S line	House	5.0
E from E line	House	11.0
Pipe inside property		8.0

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

8/4/04 - This service replaces Service # 13847. Service reduced to 3/4" and tied into existing copper before curb stop, service installed prior to Chapter 90 Princeton St. Project, lead replaced before paving, no service # was issued at the time.

[illegible]

CHARGE OUTS

[illegible]

110

APPLICATION No.: 13847

TAP CLEARED

LOCATION: 9 Irvington Ct.

OWNER: Mrs Saml. Haud

MEASURES: 5/8"

N from

Princeton

82.2 ft.

E from W line

Irvington

8.0 ft.

N from S line

house

9.5 ft.

Oct. 27, 1976 Renewed from 4½ ft. west of curb stop to a point 4 ft. east of curb stop. Cut-in a 3/4" curb stop at a point 4 ft. E x curb stop (buried - on position) 8½ ft. - 3/4" Copper tubing
 2 - 3/4" Curb Stops Caldwell Stop Box
 2 - 5/8" x 3/4" lead to cop. adaptorXXS

2/9/93: Renewed from main to a point ft Stock: 5ft 3/4" copper tubing 1-3/4" curb stop 1-Caldwell stop box 1-3/4x5/8 lead-cop adapt.xs 1-3/4x5/8 Fig 413
 =====

August 1994 Nelson Cardosa renewed from the curb stop to the cellar. This service had been shut off since 12/7/92.
 Turned on & Set 10/24/94

NOTE: City will renew from main on Princeton St. to curb stop at a later date - per Water Board

July 11, 1995 Installed 3/4" cop to cop cplg. 3 ft. E x curb, Installed 6 ft. - 3/4" copper curved going south, installed 5/8" x 3/4" lead to copper adapt XXS at a point 3 ft. S x curb stop.

If this service is renewed from Princeton St., it should be done to the curb stop in sidewalk.
 6 ft. - 3/4" copper tubing 1 3/4" x 3/4" cop to cop cplg. comp.
 5/8" x 3/4" lead to cop adapt XXS

DATE

BEF.

AFT.

REMARKS

1-21-93

T9300 715-04

2/9/93: tap reamed

95280279

12/13

955001926

7-26-04

10:00

2004-300-5980

Small main leak from Princeton St.
 main.

[illegible]

1911
ACCEPTED ST.