

#4559

APPLICATION No.: #33212

TAP CLEARED

LOCATION: Acushnet Ave., N x Sassaquin Ave.

OWNER: Sassaquin Village Associates, LLC

31-313

MEASURES: 8" D.I. June 14, 2006

Measures of 8" Gate Valve:

S x hydrant #5-0003 199.0 ft.

E x W line Acushnet Ave. 15.0 ft.

S x S line #4571 Acushnet Ave. 32.5 ft.

E x E line #4571 Acushnet Ave. 28.0 ft.

Chris Mendoza Co. installed 8" line to supply 2 condos on

Lot 28 &amp; 29

36" x 8" Tapping sleeve

8" Tapping gate valve

8" DI pipe

Service installed westerly to supply Condos on Lots 28 & 29, then  
southerly apporx. 27 ft. to a Hydrant at terminus.3/19/09 - North End Pressure Project - City crew tied this 8"  
fire supply to new 12" water main in Acushnet Ave  
24 ft - 8" ductile iron pipe; 1 - 8" 441; 2 - 8" 22.5 bends;  
1 - 8" cap. Foreman: Frank Bento

## METER HISTORY

[illegible]

## CHARGE OUTS