

FUTURE SERVICE

APPLICATION No.: #33234

TAP CLEARED

LOCATION: ~~24~~ Blackmer St., NS, E x Front St. 235.6 ft.

OWNER: FIRE SUPPLY

31-313

Lot #52 Formerly hot

MEASURES: 6" D.I.

October 8, 1999^{1A}

Measures of 6" Gate Valve:

E x E line Front St.

235.6 ft.

N x S line Blackmer St.

17.0 ft

Main is 14 ft. N x S line

D.W. White installed the following:

12" x 12" x 6" Tee

1.6 ft. 6" Ductile pipe

6" Mueller Gate Valve, MJ

#10 Gate Box, compl.

Approx. 7 ft. 6" Ductile pipe to a 45 degree bend going down

1.6 ft. 6" Ductile pipe to a second 45 degree bend

29.4 ft. 6" Ductile iron pipe from bend to end of service

SEE SKETCH

4 ft. 3/4" thrd rod

4 - eye bolts

Insp by: M Rose, III

DATE

BEF.

AFT.

REMARKS

METER HISTORY

[illegible]

CHARGE OUTS