

FUTURE SERVICE

#43

APPLICATION No.: #33236

TAP CLEARED

LOCATION: Blackmer St., NS, E x Silva St. 62.5 ft.

DATE BEF. AFT. REMARKS

OWNER:

Lot #1 Formerly

31-313

MEASURES:

6"

D.I.

October 8, 1999 Lot #2

Measures of 6" Gate Valve:

E x E line Silva St. 62.5 ft.

S x N line Blackmer St. 33.5 ft.

6" gate is N x main 3.0 ft.

Pipe inside property 4.5 ft.

Main is 14 ft. N x S line Blackmer St.

D.W. White installed the following:

12" x 12" x 6" Tee

40 ft. 6" Ductile pipe

6" Mueller Gate Valve, MJ

#10 Gate Box, compl

6 ft. 3/4" thrd rod

8 - 3/4" eye bolts

8 nuts/washers

INACTIVE

SER

The following installed from 6" Gate Valve:

14" pc of 6" ductile iron pipe to a 45 degree bend down
under sanitary sewer

a 16" pc - 6" ductile iron pipe to second bend going North

a 18' pc north under 24" storm drain to a second 18 ft. pc

6" ductile iron pipe

SEE SKETCH

METER HISTORY

[illegible]

CHARGE OUTS