



APPLICATION No.: #33303

TAP CLEARED

116 LOCATION: Ruth St., opposite Viall St.

OWNER: Ed Allard

Lot #300

31-313

MEASURES: 2"

Copper

January 8, 2007

REPLACES SERVICE #19894

E x E line Viall ST. 15.0 ft.

N x S line Ruth St. 7.0 ft.

E x W line house 9.0 ft.

W x E line house 41.0 ft.

N x N line building 22.8 ft.

Main to line 18.0 ft.

Pipe inside property 18.0 ft.

DATE

BEF.

AFT.

REMARKS

[illegible]

116 RUTH ST.

APPLICATION No.: 19894

TAP CLEARED 82230973 ✓

LOCATION: 116 Ruth St. & 45 Salisbury St.

OWNER: St. Anne's R. C. Parish

MEASURES: 2" Cement Lined Dec. 7, 1923
 Darling gate I. box
 E from Viall St. 47.3 ft.
 N from S line Ruth St. 17.2 ft.
 W from E line School St. 11.1 ft.

June 16, 1982 Repaired 2" gate valve - gate was broken closed position.

New bonnet & valve complete, 6 - 2" x 3/8" bolts with nuts

New gasket

1 Caldwell Gate Box, top section

Replaced by # 33303

[illegible]

CHARGE OUTS

[illegible]

Bill to domestic Service #33303

114

APPLICATION No.: #33304

LOCATION: Ruth St., opposite Viall St.

OWNER: Ed Allard

Lot #300

31-313

MEASURES: 4"

D.I.

December 8, 2006

FIRE SUPPLY

Measures of 4" gate valve:

E x E line Viall St.

12.0 ft.

N x S line Ruth St.

16.6 ft.

E x W line building

6.0 ft.

W x E line building

43.0 ft.

N x N line building

32.0 ft.

Main to line

18.0 ft.

Pipe inside property

18.0 ft.

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]