

APPLICATION No.: 33440

## TAP CLEARED

LOCATION: 10 Front St.

OWNER:

31-313

MEASURES: 8-10 Ductile Iron - Fire Supply 5/15/08

N from	Wamsutta St	230.0
S from	Hydrant	4.0
W from E line	No. Front St	31.0
N from N line	Building	2.0
N from S line	Building	103.0
W from W line	Building	178.0
Main to property line		18.0
Pipe inside property		258.3
N from Service Connection		27.0

5/1/08 - Inspection of fire supply - Percy Reynolds  
Installation and materials supplied by Ace Asphalt (Fairhaven Exc)

5/15/08 - Pressure test by Percy Reynolds  
1 hr @ 150 PSI - Passed

-----

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

[illegible]

## CHARGE OUTS

[illegible]