

✓

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

31-313

MEASURES: 6" Fire Supply D.I. 5/8/08

|               |           |      |
|---------------|-----------|------|
| N from N line | Centre St | 29.0 |
|---------------|-----------|------|

|                |      |
|----------------|------|
| S from Hydrant | 16.0 |
|----------------|------|

|               |          |     |
|---------------|----------|-----|
| N from S line | Building | 4.0 |
|---------------|----------|-----|

|               |          |      |
|---------------|----------|------|
| S from N line | Building | 32.0 |
|---------------|----------|------|

|                       |      |
|-----------------------|------|
| Main to Property Line | 13.0 |
|-----------------------|------|

|                      |     |
|----------------------|-----|
| Pipe inside property | 2.0 |
|----------------------|-----|

5/8/08 - Reis Asphalt installed and supplied all materials.

Reis Asphalt charged \$100 for Inspection (overtime)

Inspected and pressure tests passed. Inspections by: Manny Rose  
& Percy Reynolds

[illegible]

## CHARGE OUTS

[illegible]