

✓

33451

✓

REMARKS

OWNER: Manuel Mello (M & C Restaurant) Contractor: DPI

31-313

MEASURES: 4" Ductile Iron (Fire Supply) 7/9/2008

E from E line Belleville Ave.

W from Hydrant	154.0
----------------	-------

N from S' line	Phillips Ave	16.0
----------------	--------------	------

E from W line	Building	35.0
---------------	----------	------

W from E line	Building	10.0
---------------	----------	------

N from N line	Building	16.0
---------------	----------	------

Main to property line	18.0
-----------------------	------

Pipe inside property	2.0
----------------------	-----

7/9/08 - City crew installed & supplied materials for service

1 - 10" x 10" x 4" Tapping sleeve; 1 - 4" gate; 1 - 4" 441;

20 ft - 4" ductile iron pipe; 1 - #10 gate box

Foreman: Danny Perry

METER HISTORY

[illegible]

CHARGE OUTS