

APPLICATION No.: 33473

## TAP CLEARED

LOCATION: 701 Orchard St N x Cove Rd

DATE

BEF.

AFT.

REMARKS

OWNER: Club Uniao Faialense (Roy Oliveira) Contractor"

31-313

W.C. Smith &amp; Sons

## MEASURES:

6" Du ctile Iron (Fire Supply) 8-05-2008

N from W line Rockdale Ave 161.4

N from Hydrant # 1-0120 25.0

E from W line Orchard St 15.0

S from N line Building 29.0

N from S line Building 15.0

House to Box (service) 23.0

S from Domestic Service 7.0

Main to Property line 27.0

Pipe inside property 8.0

8/5/08 - WC Smith & Sons installed new 6" fire supply from main  
to building. Pressure test - passed, contractor  
charged \$150 for pressure test. Inspected:Percy Reynolds

-----

[illegible]