

WATER SERVICE

APPLICATION No.:

33608

33608

9647

TAP CLEARED

LOCATION:

613 Elm St

p 50

L 392

OWNER:

31-313

MEASURES:

Contractor: Perrina Construction

1"

Copper

10-01-2008

E from E line Francis St

66.3

S from N line Elm St

6.0

W from E line House

44.6

On E line House

S from S line House

10.7

Main to Property Line

26.0

Pipe inside Property

10-01-08 - Work performed under West End Water Main
Rehab Project - Contract # 4.
Installed from main to curb stop

1/3/17. Renewal curb stop to cellar Contractor: JLC
Construction Inspector: P Reynolds

DATE

BEF.

AFT.

REMARKS

[illegible]

APPLICATION No.:

9647

TAP CLEARED 8/08 2224

LOCATION: 613 Elm

OWNER: Mrs. Rose Wamboldt

MEASURES:

01/01/1899

18-17-08

3/4"

N from	Elm	2.5
E from Wline	Reed	6.5
N from S line	House	1.5

Feb. 21, 1984 - Renewed from 1 ft. outside curb stop to property line.

7.6 ft. - 3/4" copper tubing

1 - 3/4" curb stop 1 stop box

2 - 3/4" x 3/4" lead to copper adaptors XS

8-17-99 Renewed from curb stop to a point 4 ft. ins. property line. Stock: 11 ft. 3/4" Copper tubing,

1 - 5/8" x 3/4" lead to cop. adapt. XXS.

9/24/08 - West End Water Main Rehab Contract #4-Perrina Const renewed service from the main to a point 1.3 ft inside curb stop

8.5 ft - 1" copper tubing; 1 - 1" corp tap; 1 - 1" curb stop;

1 - 1" x 3/4" reducer. Inspected by Tim Ives, CDM

DATE

BEF.

AFT.

REMARKS



7/17/99 1959 3306536

[illegible]

CHARGE OUTS

[illegible]