

APPLICATION No.: 33694

TAP CLEARED

LOCATION: 29 Whitman St

DATE _____

BEF

AFT.

REMARKS

OWNER:

New Bedford Housing Authority

31-313

Contractor: JM Shaw Construction

MEASURES:

4" Ductile Iron Fire Supply 05-16-2011

N from N line Whitman St 215.0

W x Hydrant	12.8
-------------	------

N from N line Whitman St 215.8

W from E line Building 29 14.6

E from W line Building 31	25.8
---------------------------	------

S from W line Building	51	29.0
S from S line Building		13.0

S x Hydrant	5.0
-------------	-----

Main to Property Line

Pipe inside property	146.8
----------------------	-------

W from W line Desautels St	102.0
----------------------------	-------

NOTE: 6" Transite sewer running N x S 18.5 ft W x Hydrant

NOTE: There is only 1 shut-off valve for both Fire Supply

Services (# 33694 & # 33695)

5/16/11 - JM Shaw installed this Fire Supply. Inspected

by Percy Reynolds

[illegible]

CHARGE OUTS

[illegible]