

APPLICATION No.: 33714 - FS

LOCATION: 15 Antonio Costa Ave P 99 L 66

OWNER: Seawatch

31-313

MEASURES: Contractor: Pontes Excavation

8" Ductile Iron - Fire Supply 10/12/11

E from E line Herman Melville Blvd	477.0
E from Hydrant	137.0
N from S line Antonio Costa Ave	15.0
E from W line Building	133.0
W from E line Building	17.0
S from S line Building	84.0
Main to Property Line	37.0
Pipe inside Property	52.0

10/12/11 - Pontes Excavating installed this 8" Fire Supply

Note: Service enters W x E line of new addition 3.0

Inspected by Percy Reynolds

TAP CLEARED

DATE	BEF.	AFT.	REMARKS
------	------	------	---------

METER HISTORY

[illegible]

CHARGE OUTS

15 Antonio Costa

