

APPLICATION No.: 33773

TAP CLEARED

LOCATION: 109 William St

OWNER:

31-313

MEASURES:

6inch Fire Supply

E from E line Pleasant St 51.5ft

S from N line William St 30.6ft

W from E line Building 22.0ft

E from W line Building 51.5ft

S from N line Building 30.6ft

Main to property line 32.0ft

Pipe inside property 5.0ft

1/13/13 W.C. Smith laid fire supply service Inspected
P.Reynolds2/25/13 Fire supply service turned on P.Reynolds Turn on
fee was paid with permit fee.

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]