

21

APPLICATION No.: 34042 - FS

TAP CLEARED

LOCATION: ~~73~~ Cove Street

OWNER:

31-313

MEASURES:

8" FIRE SUPPLY P.21 L.53

Storage Facility

E x E line Viall St 17.0'

S x N Line Cove St 38.0'

W x W line building 17.0'

S x S line building 38.0'

Main to property line 39.5'

pipe inside property 28.0'

6-12-2019: New service installed by Century paving
Test Pressure 200 PSI 2hour Static 90 PSI

DATE

BEF.

AFT.

REMARKS

[illegible]