

#423

FKA
LOCATION: 1060 Pleasant St

APPLICATION No.: 34065 4FS

P. 66 L. 28

TAP CLEARED

OWNER: _____

31-313

MEASURES:

4" fire supply

Nearest street to box EXE Pleasant St 40.0

Other location WXW Purchase St 164.8

Property line to box NXS Campbell St 16.5

Corner of building to box EXW 34.8

Corner of building to box 29.0

House to box SXS house 55.2

Main to property line NXS Cambell St 14

Pipe inside property 32

11/26/2019 - New service installed by WC Smith
inspected by Manuel Rose12-5-2019: PRESSURE TEST WC SMITH
INSPECTED BY MANUEL ROSE PASSED
200PSI LENGTH OF MAIN 57'

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]