

APPLICATION No.: 34105

LOCATION: 214 Samuel Barnet Blvd

OWNER:

31-313

MEASURES: P. 133, L. 55

Connecting to 12" water main on Flaherty Dr
32347 to be disconnected in future

```
S x gate valve @ samuel barnet 446.0'
s x n line building      222.0'
n x s line building      89.0'
w x w line building      71.0'
Main to property line    34.0'
Pipe inside property     67.0'
```

12-21-2020 - no meter to be placed until
32347 is cut & capped.

Inspected new service 12-8-2020 & 12-9-2020
Contractor MHT Excavating
Inspector P.Reynolds

12-16-2020: Pressure Test PASSED conducted by
WINWATER Length of main 94.5
1 Gate Valve, Test Pressure 150PSI
Static Pressure 55PSI Witnessed by P. Reynolds

[illegible]