

APPLICATION No.:

TAP CLEARED

LOCATION:

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

Service#34161

MEASURES:

P.52/208 L.209 +342

Mechanics Lane NS William s 80' W x Sixth St  
proposed community theater performing arts

6" DI FIRE SUPPLY

3' NORTH

E from W LINE building 12" – 10

W from E Ling Bldg 40" 2"

Main to property line 9-10" North

Pipe Inside 18"

3" offset over 20" sewer

1" below 4" conduit

09/14/22: INSPECTION WITNESSED BY RONNIE AGUIAR, 3' OFFSET OVER 20" SEWER, 1" BELOW 4"  
CONDUIT: NEW FIRE SUPPLY SERVICE INSTALL BY WC SMITH- AARON SMITH. NEW SERVICE # 34161  
Disturbance #340-2022

[illegible]