

APPLICATION No.: 3568

TAP CLEARED

LOCATION: 150 Purchase St.

OWNER: Manuel P. Alexander

MEASURES:

 $\frac{1}{2}$ "

H lead

Jan. 3, 1880

N from

Potomaska St.

45.0 ft.

W from E line

Purchase St.

6.2 ft.

N from S line

house

1.9 ft.

 October 22, 1963 Renewed from curb stop to property line.
 7 ft. of $\frac{3}{4}$ " copper tubing 1 $\frac{3}{4}$ " copper coupling A-1525
 1 lb. wiping solder

July 2, 1989 - dug to locate leak - found leak at 140 Purchase St.

1-22-99 Renewed from main to curb stop. Found copper from
 curb stop to inside cellar. Stock: 22'- $\frac{3}{4}$ " Copper tubing
 1 - $\frac{3}{4}$ " Curb Stop, 1 - Caldwell Stop Box, 1 - $\frac{1}{2}$ " x $\frac{3}{4}$ "
 Fig. 413. This work done due to letter with high lead count.

DATE

BEF.

AFT.

REMARKS

1-22-99 Tap reamed
 1-7-99 19990201045

[illegible][illegible]