

APPLICATION No.: 3631

TAP CLEARED ✓

LOCATION: 62 Forest St.

OWNER: Helena G. Mackenzie

DATE

BEF.

AFT.

REMARKS

6/17/77

Tap reamed

MEASURES: 5/8" H lead May 12, 1880

W from County St. 111.0 ft.

N from S line Forest St. 6.9 ft.

W from E line house 3.0 ft.

Nov. 17, 1969 Renewed from 6" outside of curb stop. to 6 ft.
 inside of the curb stop 6½ ft. - 3/4" copper tubing
 3/4" Hays curb stop 2# wiping solder

Dec. 18, 1974 Renewed from 6" outside curb stop to
 inside cellar.

18 ft. - 3/4" copper tubing (10 ft. inside)

3/4" Curb Stop ~~3/4" Curb Stop~~

Caldwell Stop Box 5/8" x 3/4" lead to copp.
 adaptor XS

June 17, 1977: Leak at tap. Repaired from main to curb stop.

7 ft.-3/4" copper; 3/4" x 3/4" Figure 413; tap reamed;

July 18, 1989 Renewed from newly installed 6" main to a point 1 ft.

1 ft. - 3/4" copper tubing 1 - 3/4" corp. tap

1 - 3/4" x 3/4" cop to cop cplg., comp.

[illegible]

CHARGE OUTS

[illegible]