

APPLICATION No.: 3723

TAP CLEARED ✓LOCATION: 408 Mill, Cor. FlorenceOWNER: J.J. MunerkMEASURES: $5/8"$

S from

Mill

30.1 32.3 ft.

W from E line

Florence

5.5 6.9 ft.

N from S line

House

6.7 32.6 ft.

Nov. 20, 1958 Renewed from main to a point 4 ft. inside
curb stop. The curb stop is 3 ft. north from tap.

The old lead left in ground.

28 ft. - $3/4"$ copper tubing

$3/4"$ x $3/4"$ cop to cop stop

$3/4"$ cop stop fig. 415

fig. 413

Stop Box

$3/4"$ cop to cop cplg.

- - -

Oct. 22, 1951 Renewed from $2\frac{1}{2}$ ft. on house side of
curb stop to inside cellar.

7 ft. - $3/4"$ Copper tubing

- - -

[illegible]

CHARGE OUTS

[illegible]

Service Leak
408 Mill St.

November 20, 1958

Renewed from main to a point 4 ft. inside curb stop
The curb stop is 3 ft. north from tap. The old lead
was partly left in ground and the old stop box was
partly left in ground near tree.

28 ft. of 3/4" copper tubing type K, soft

/ 1-3/4" x 3/4" cop. to cop. stop, fig. 413

/ 1-3/4" cop. to cop. stop, fig. 415

/ 1 C. I. stop box, complete

/ 1-3/4" cop. to cop. cplg., A-1525

Tap reamed - Ingersoll Rand: 2 hrs.

1 street cut: 4' x 2' Warrenite

1 sidewalk cut: 3' x 2' cement

Handwritten:
Hunt
view
BWA

(over)

Location of New Stop Box:

S x S line Mill St.	30.1
W x E " Florence St.	5.5
N x S " House	6.7

