

APPLICATION No.: 3730

TAP CLEARED

LOCATION: 302 Purchase St.

OWNER: Armand A. Langis, Et Ux

MEASURES:

5/8" H lead Sept. 11, 1880
 N from Grinnell St. 97.9 ft.
 W from E line Purchase St. 6.5 ft.
 N from S line house 8.0 ft.

March 25, 1966 Service renewed from $\frac{1}{2}$ ft. outside curb stop to prop
 property line.

8 $\frac{1}{2}$ ft. of 3/4" copper tubing 1 3/4" copper to copper stop
 1 3/4" copper coupling A-1525 1 lb. Wiping solder

August 23, 1960 Renewed with 2 ft. of 3/4" (copper tubing) from
 corporation tap to a point 2 ft. from tap.

2 ft. of 3/4" copper tubing 1 lb. wiping solder

October 11, 1958 Renewed from property line to inside cellar.

4 ft. of 3/4" copper tubing

Stock supplied and installed by owner's plumber.

July 10, 1950 Repaired leak at tap.

1 ft. of 3/4" copper tubing 1 3/4" I.P.F x 3/4" cop. coupling

DATE

BEF.

AFT.

REMARKS

7/27/13

Tap reamed
 2013-3001375

[illegible]

CHARGE OUTS

APPLICATION No.: 3730

TAP CLEARED

• LOCATION: 302 Purchase St

OWNER: Armand A. Langis, Et Ux

31-313

MEASURES:

07/27/13 City crew renewed service from main to curb stop
Stock: 20ft - 3/4" copper tubing; 1 - 3/4" curb stop;
1 Caldwell stop box; 1 - 5/8"x3/4" Fig 413; Tap reamed.
J.Medeiros

[illegible]

[illegible]

422

NOTA

GENY