

APPLICATION No.: 3880

TAP CLEARED

LOCATION: 101 Potomska St.

OWNER: Manuel Cordeiro, Et Ux

MEASURES:

$\frac{1}{2}$ " H lead Oct. 18, 1880

W from Second St. 62.5 ft.

S from N line Potomska St. 7.2 ft.

E from W line house 1.6 ft.

✓ April 25, 1962 Renewed from curb stop to inside building.
15 ft. 3/4" copper tubing 1 lb. wiping solder

July 23, 1962 Renewed $\frac{1}{2}$ ft. outside curb stop.
 $\frac{1}{2}$ ft. $3/4$ " copper tubing 1 $3/4$ " cop. to cop. stop
 1 lb. wiping solder

Nov. 8, 1976 Renewed from the curb stop to a point 2 ft.
outside curb stop.
2 ft. - 3/4" Copper tubing 5/8" x 3/4" lead to
cop. adapt. XXS

Aug. 2, 1989 Renewed from newly installed 6" ductile main to a point 1 ft.
 Brito Const. supplied all stock:
 1 ft. - 3/4" copper tubing 1 - 3/4" corp. tap
 1 - 5/8" x 3/4" lead to cop. adapt XS

[illegible]

CHARGE OUTS

APPLICATION No.: 3880

TAP CLEARED

LOCATION: 101 POTOMSKA ST

OWNER: MANUEL CORDEIRO ET UX

MEASURES: 1/2" H.LEAD Oct 18,1880

W FROM SECOND ST 62.5 ft

S from N line POTOMSKA ST 7.2 ft

E from W line HOUSE 1.6 ft

Feb 25,1997:

Service tap was pulled by DPW digging sewer line

✓ Renewed from main to a point 2ft in front of main

Stock: 2ft 3/4" copper tubing 1-3/4x5/8 lead-cop adapt.xs

1- 3/4" corporation tap =====

✓ 10/28/03 Renewed from main to property line. Stock:

30 ft. 3/4" copper tubing; 3/4" curb stop; Caldwell
stopbox; 3/4" x 3/4" Fig 413 Tap ReamedRepaired broken sewer in street and in sidewalk.

DATE

BEF.

AFT.

REMARKS

10/28/03

2003 4402677

10/28/03

Tap reamed

[illegible]

CHARGE OUTS

[illegible]