

APPLICATION No.: 3913

TAP CLEARED

LOCATION: 84-86 Acushnet Ave

DATE

BEF.

AFT.

REMARKS

OWNER:

'31-313

MEASURES: Dec 24, 1880

E from Acushnet Ave 39.2'

S from N line Potomska St 7.3'

W from E line house 0.9'

1" COPPER

11-1-2018: Lead service line replacement program
phase 1: TYPE CU, Diameter 1, Water Pressure 90

Contractor: P. Gioioso & Sons

Distance from main to curb stop 19.4'

Distance curb stop to meter 12.8'

Distance from curb face to curb stop 1.3'

Depth of service 4.1'

Total length of new pipe installed 32.2'

Curb stop replaced: NO Size 1"

Corporation replaced: YES Size 1"

Ball valve furnished: YES Size 1"

remarks: existing corporation was 1" not reeplaced

[illegible]