


APPLICATION No.: 3958TAP CLEARED LOCATION: 62 ThomasOWNER: A.E. HoughtonMEASURES: 3/4"

S from	Maxfield	83.8 ft.
W from E line	Thomas	7.0 ft.
N from S line	House	12.5 ft.

6/29/79: Franklin renewed service from the main to the meter. 31 ft. $3/4$ " copper (6 ft. ins.); $3/4$ " curb stop; Caldwell stop box; 1" corp. tap.

Aug. 3, 1983 Renewed cracked main.

1- 4 " x $3/4$ " 10 inches wide Adams Clamp

1- $3/4$ " copp. tap 2 ft. $3/4$ " copper tubing

1- $3/4$ " x $3/4$ " cop-cop compression coupling

- - - -
May 9, 1995: S & B const. renewed service from the newly installed 8" main to a point 5.2ft All stock supplied & installed by contractor 5.2ft $3/4$ " copper tubing 1- $3/4$ x $3/4$ cop-cop cplg,comp 1- $3/4$ " corporation tap
S & B cont. to maintain cut_____

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS
