

Service Killed at Tap

APPLICATION No.: 3085 3985

TAP CLEARED 8544-0332

LOCATION: 325-9 County St. (24 Allen St)

OWNER: Jose N. Da Costa

MEASURES: $3/4"$

~~H lead~~

June 18, 1881

10/16/86:TAP REAMED

8642-1093

8646-00 7/1

W from

County St.

50.9 ft.

N from S line

Allen St.

6.4 ft.

E from W line

bldg.

8.7 ft.

✓ 10/29/85: Renewed from ½' outside curb stop to ins. cellar.
(2.0 ft. ins. prop line) Stock: 11.0 ft. 3/4" copper tubing
1 - 3/4" curb stop 1 - Caldwell stop box 1 - 3/4x3/4 lead to cop
adapt. xxs.

✓ 10/16/86: Renewed from main to curb stop. Stock: 8.0 ft. 3/4" copper tubing 1 - 3/4" curb stop used old Caldwell stop box 1 - 3/4 x 3/4 cop to cop sweat elbow 1 - 3/4 x 3/4 Fig. 413

8/8/2012 Leone Engineering Killed this service at the tap - Inspected by Percy.

[illegible]

CHARGE OUTS

[illegible]