

APPLICATION No.: 4017

LOCATION: 125 Parker st

OWNER:

31-313

MEASURES: 3/4"

9/18/89 renewed outside c/s to prop line

stock: 7 ft 3/4" copper tubing

1-3/4" curb stop

1 - caldwell stop box

$2\frac{3}{4} \times \frac{5}{8}$  lead to cop adapt xxs

10/4/1971 renewed main to a point 6ft from main

6 ft - 3/4" copper tubing

1 wiped joint 1" x 3/4" fig. 413

11/30/94 renewed main to curb stop

stock: 19 ft 3/4" copper tubing came c/s

same caldwell stop box 1-3/4" x 3/4" fig 413

2005 south shore utility renewed main to PL

6/7/17 jlc renewed c/s to meter

new measurements

E x E line chancery 12.4'

S x N line parker 6.7

W x E line house 12'

E x W line house 8'

S x S line house 10.6

main to prop line 26'

pipe inside property 6'

TAP CLEARED

DATE \_\_\_\_\_

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.:

4619

4017

TAP CLEARED 8938-00531

LOCATION: ~~121~~ Parker Cor. Chancery~~121~~ Parker St. in computer

DATE

BEF.

AFT.

REMARKS

OWNER: John Sylvia

MEASURES:

3/4"

E from

hancery

12.4 ft,

S from N line

Parker

6.7 ft

E from W line

House

9.7 ft.

11-30

94

9448-02680

11/30/94: TAP REAMED

9/18/89: Renewed from lft. outside curb stop to prop line

Stock: 7 ft. 3/4" copper tubing 1-3/4" curb stop

1 - Caldwell stop box 2-3/4x5/8 lead to cop adapt. xxs.

Oct. 4, 1971 Renewed from the main to a point 6 ft. from <sup>the</sup> hte main.  
 6 f t. - 3/4" copper tubing 1 wiped joint 1" x 3/4" fig. 413

11/30/94: Renewed from main to curb stop

Stock: 19ft 3/4" copper tubing same curb stop

same Caldwell stop box 1-3/4x3/4 Fig 413

2005 South Shore Utility renewed service from main to  
 property line.



[illegible]

## CHARGE OUTS

[illegible]