

APPLICATION No.: 4164

TAP CLEARED ✓

LOCATION: 23 So. Sixth Cor. SchoolOWNER: Elks Lodge

MEASURES: 1"  
W from Sixth 61.8 ft.  
N from S line School 7.0 ft.  
E from W line Body of House 12.3 ft.

-----  
August 11, 1964 Renewed from property line to inside cellar.  
10 ft. of 1" copper tubing  
Stock supplied and installed by owner's plumber.  
-----

OCT 12 1979 Franklin renewed service from the main to the prop. line.  
17 ft.-1" copper  
1-1" x 1" Fig. 413  
1-1" curb stop 1-Caldwell stop box  
1-1" x 1" cop.-cop. adapt.

2/27/02 Checked on Sixth St. from Int. Sixth St. southerly for 120 ft. for leak.  
Drilled holes over main. found no leak at #23. Found water sipping thru under blacktop  
from parking lot of above property.

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]