

APPLICATION No.: 4326

TAP CLEARED

LOCATION: 83 Linden

OWNER: Ann Griffith

MEASURES: 5/8¹¹

from

S from N line

E from E line

Reynolds
Linden
house

12-1-1882

30.0 ft.

7.1 ft.

3.4 ft.

DATE _____

BEF.

AFT.

REMARKS

2/19/68

Reamed

4/2/76

Reamed

Feb. 19, 1968 Leak at corp. tap.
Coupling was loose & tightened.

April 2, 1976 Renewed from the main to inside cellar.
43 ft. - 3/4" Copper tubing (17' inside)
3/4" Curb Stop Stop Box
5/8" x 3/4" Fig. 413

Stop Box

[illegible]

CHARGE OUTS

[illegible]