

4346

APPLICATION No.:

TAP CLEARED

LOCATION: 76 Acushnet Ave

OWNER:

31-313

MEASURES:

Dec 8, 1882

E from Acushnet Ave 12.2'

N from S line Potomska St 6.9'

W from E line bldg 9.9'

1" COPPER

5-14-2019: Lead service line replacement program
phase 1: TYPE CU, Diameter 1, Water Pressure 100

Contractor: P. Gioiosio

Distance from main to curb stop 9.3'

Distance curb stop to meter 10.9'

Distance from curb face to curb stop 1.4'

Depth of service 4.2'

Total length of new pipe installed 20.2'

Curb stop replaced: YES Size 1"

Corporation replaced: YES Size 1"

Ball Valve furnished: YES Size 1"

[illegible]