


APPLICATION No.: 4428TAP CLEARED LOCATION: 201 Grinnell St.OWNER: Myron M. NavisonMEASURES: 5/8" H lead May 4, 1883

N from Grinnell St. 52.6 ft.

E from W line Orchard St. 6.8 ft.

S from N line porch 4.8 ft.

6/13/06 Renewed from main to property line. Stock: 6 ft.
3/4" copper tubing; 3/4" curb stop; Caldwell stop box;
5/8" x 3/4" lead=cop adapt. XXS; 5/8" Fig. 413
Tap Reamed

1" Copper Service

09/13/2018 Lead Service Line Replacement Program

Phase 1, Contractor P Gioioso & Son

Type CU, Diameter 1in, Water pressure 80

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 20.5

Distance from curb face to curb stop (ft) 1

Depth of service (ft) 4

Total length of new pip installed (ft) 20.5

Curb stop replaced: no Corporation replaced: no

Ball valve furnished: yes size 1"

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
3-18-71		5/8	Hersey H.F.	5097234					

CHARGE OUTS

