

APPLICATION No.: 4464

TAP CLEARED

record
not found in
fileLOCATION: 2185 Purchase

OWNER: _____

MEASURES: 5/8"

S from Sawyer 168.0 ft.

E from W line Purchase 7.8 ft.

S from N line House 9.3 ft.

1/18/79-Renewed 6" outside curb stop to 2.6 ft. inside
curb stop 1 3 ft. - 3/4" copper; 3/4" curb stop/ 2-5/8" x
3/4" lead-cop. adapt. XXS; Caldwell stop box; Side.

9/7/06 - Caliacco Corp. renewed from main to property line 17.5 ft

Cannot Log into Computer

INACTIVE SER

DATE

BEF.

AFT.

REMARKS

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 21507

LOCATION: E.S. County St. 1070 S. Sawyer

OWNER:

MEASURES:	6"	Del.	12-24-30
	6" Dar. tap gate I box		
	S from	Sawyer	140.5 ft.
	E from W line	Purchase	116.0 ft.
	S from N line	Bldg.	5.3 ft.

FIRE SUPPLY

Dec. 30, 1991 Repaired cracked 6" CI fire supply under curb line
against west side of tel. duct. (10.0 ft. E x W line Purchase St.)
Cut out 13" pc. & replaced with 13" of 6" ductile pipe
2 - 6" Omni cplgs. (Pipe was split)

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

12/30	9201	0032
-------	------	------

[illegible]

CHARGE OUTS

[illegible]