


APPLICATION No.: 4527TAP CLEARED LOCATION: 167 Grinnell St.OWNER: Duarte Rebeiro

DATE

BEF.

AFT.

REMARKS

9/7/65

reamed

MEASURES: 5/8" H lead Sept. 7, 1883E from Crapo St. 50.5 ft.S from N line Grinnell St. 6.5 ft.W from E line House 7.0 ft.

Sept. 7, 1965 Renewed from main to  $\frac{1}{2}$  ft. outside curb stop  
 5/8" reused corporation cplg. 1 lb. wiping solder  
 18 ft. of 3/4" copper tubing

Sept. 20, 1965 Renewed service from  $\frac{1}{2}$  ft. outside curb stop to  
 property line  $7\frac{1}{2}$  ft. 3/4" copper tubing  
 3/4" cop. to cop. stop, fig. 415 1 lb. wiping solder  
 3/4" copper coupling, A-1525

1" Copper Service

09/17/2018 Lead service line replacement program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 90

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 21.5

Distance from cur face to curb stop (ft) 1

Depth of service (ft) 4

Total length of new pipe installed (ft) 21.5

Curb stop replaced: NO, Corporation Replaced: NO

Ball valve furnished: yes size 1"

[illegible]