

APPLICATION No.: 4535

## TAP CLEARED

LOCATION: 77 Dartmouth St

DATE

BEF.

AFT.

REMARKS

OWNER:

31-313

MEASURES:

Sept 11, 1883

N from Washington St 33.5'

E from W line Dartmouth St 7.8'

E from E line House 13.3'

N from S Line House 8.7'

1" COPPER SERVICE

9-13-201: Lead service line replacement program  
phase 1, Contractor P. Gioioso & Sons

TYPE: CU, Diameter 1, Water Pressure 80

Distance from main to curb stop 26'

Distance curb stop to meter 16.9'

Distance from curb face to curb stop 1.0'

Depth of service 3.9'

Total length of new pipe installed 16.9'

Curb stop replaced: NO Size 3/4"

Corporation replaced: NO Size 3/4"

Ball Valve furnished: YES Size 1"

Remarks: 1-3/4" union installed 1.0 LF outside curb stop

[illegible]