

APPLICATION No.: 4550

TAP CLEARED ✓

LOCATION: Parker Cor. 62 Shawmut Ave.

OWNER: Dr. John Machads

MEASURES:

3/4"

Copper

01-01-1882

9/10/97: tap reamed

E from

Shawmut Ave.

47.4 ft.

S from N line

Parker

7.1 ft.

W from E line

House

2.2 ft.

STreet reconstruction Sept 10, 1997

Renewed from main to prop line

Stock: 27ft 3/4" copper tubing 1-3/4" curb stop

1-caldwell stop box 1-3/4x5/8 lead-cop adapt.xxs

1- 3/4 x 3/4 Fig 413 =====

12/6/12 - New measures

E from E line Shawmut Ave

45.0

S from N line Parker St

6.0

E from W line House

38.0

W from E line House

3.0

Main to Property Line

26.0

Pipe inside Property

14.0

12/6/12 - Reis Asphalt renewed water service from curb
stop to cellar. Inspected by Percy Reynolds

NOTE: SEE NEW MEASURES ABOVE

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 4550

LOCATION: Parker Cor. 62 Shawmut Ave.

OWNER:

MEASURES:

3/4"

E from

Shawmut Ave.

47.4 ft.

S from N line

Parker

7.1 ft.

W from E line

House

2.2 ft.

TAP CLEARED

DATE

BEF.

AFT.

REMARKS



[illegible]

CHARGE OUTS

METER HISTORY									
DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

REPAIR SHOP

MR Borhelo

Date

7/3

99-32529

- check

Punch

for Piss/610

New Service

location

62 Summit Ave.

description of work

DOOR PRESSURE

THROUGHOUT HOUSE!

work done

TOLD OWNER WE

WOULD CHECK FRI 7/5 OR

MON 7/8

5 gal. @ 35 sec.

3/4 service to a 2" serving big swimming pool
and 4 washing machines

3 Tenement

signed by