

APPLICATION No.: 4655

TAP CLEARED

LOCATION: 61 Dartmouth St.

OWNER: Antonio Ferreira

MEASURES: 5/8" H lead Mar. 25, 1884

N from Grinnell St. 6.3 ft.

E from W line Dartmouth St. 8.4 ft.

June 24, 1995:

W. Walsh Cement liners removed old tap with piece of pipe cut out for entry hole. Service now tapped on new 14.7 piece ductile installed east of new gate.

Stock by city: 1-3/4" corporation tap 1.5ft 3/4" copper tubing

1- 3/4x5/8 lead-cop adapt.xxs C.L.access hole-no cut

J Rodrigues

=====

Street reconstruction Oct 21, 1997

Renewed from main to prop line

Stock: 34ft 3/4" copper tubing 1-3/4" curb stop

1-caldwell stop box same lead-cop adapt. xxs

=====

2/18/09 - City Crew renewed service from 2 ft inside curb stop into cellar (10 ft inside property line)

14 ft - 3/4" copper tubing; 1 - 3/4" x 3/4" cop to cop cplg. comp

Foreman: Frank Bento

4/5/11 - City crew repaired section of sewer service

7 ft - 6" PVC pipe; 1 - 6" clay to PVC Fernco; 1 - 4"-6"

cast iron to PVC Fernco; 1 yd - 3/4" stone; 3 yds

wrap material. Foreman: Bill Days

BRADBURY-WARING, INC.

[illegible]

CHARGE OUTS

[illegible]

APPLICATION No.: 4655

LOCATION: 61 Dartmouth St

OWNER:

31-313

MEASURES:

4/5/11 - City crew repaired water service inside private property damaged by City crew working on sewer service 6 ft - 3/4" copper tubing; 2 -3/4" x 3/4" cop-cop cplg comp. Foreman: Bill Days

TAP CLEARED

DATE _____

BEF.

AFT.

REMARKS

[illegible]

[illegible]