

APPLICATION No.: 4670

TAP CLEARED

LOCATION: 162 North

OWNER: Frank Almeida

MEASURES: 3/4" W x W line Cottage St. 106.4
~~E from Spruce 30.7 ft.~~
 N from S line North 7.1 ft. 3.9
 E from W line House 10.0 ft. 10.5
 N from N line House 8.8

 Sept. 2, 1975 Renewed from the main to a point 4 ft. from the main.
 4 ft. 3/4" copper tubing 1 1" x 3/4" fig. 413 coupling
 1 lb. wiping solder

 Sept. 2, 1975 Rewiped leaking joint at the tap.
 1 lb. wiping solder 3/4" tap reamed

 November 14, 1975 Renewed from the new 30" main in North St. to
 the property line.
 14 ft. 3/4" copper tubing 1 3/4" McDonald corp. stop, C.F.
 1 3/4" Jones curb stop, D.F. Buffalo stop box
 (No lead to copper adapter used because building is coming down;
 future Building will have copper tubing inside.)

DATE BEF. AFT. REMARKS

9-2-75

Reamed

[illegible]

CHARGE OUTS

[illegible]