

APPLICATION No.: 4683

TAP CLEARED



LOCATION: 222 State

OWNER: Mrs H Sullivan

MEASURES:

3/4"

N from

Linden

186.3 ft.

W from E line

State

7.1 ft.

N from S line

House

7.6 ft.

DATE

BEF.

AFT.

REMARKS

4/1/76

Reamed

3/11/08 8:00

2008-160 3153

3-14-08

Tap reamed

 April 18, 1966 Renewed service from 2 ft. inside curb stop to
 inside the cellar.

16 ft. of 3/4" copper tubing 1 3/4" cop to cop coupling A-1525

June 8, 1959 Renewed from main to a point 3 ft. inside curb stop
 22 ft. of 3/4" copper tubing 1 3/4" cop to cop stop
 1 lb. wiping solder 1 5/8" reused corporation

April 1, 1976 Renewed from the main to the property
 line.

26 ft. - 3/4" Copper tubing 3/4" Curb stop
 Stop Box 5/8" x 3/4" lead connector
 5/8" x 3/4" Fig. 413
 - - -

3-14-08 - City repaired tap leak, Renewed from main to a point
 2 ft

2 ft - 3/4" copper tubing; 1 - 3/4" cop to cop cplg comp; 1 -
 5/8" x 3/4" Fig. 413. Tap reamed. Foreman: Dennis Monty

[illegible]

CHARGE OUTS

[illegible]