APPLICATION No.:4787	TAP CLEARED			
LOCATION: 113 Rockland St	DATE	BEF.	AFT.	REMARKS
OWNER:				9
MEASURES: Aug 19, 1884 N X Rockland St W X E Line Bonney St S X N Line Porch 1.0 ft 1" Copper Service 10/31/2018 Lead Service Replacement Program Phase 1, Contractor P Gioioso & Son Type CU, Diameter 1in, Water Pressure 100 Distance from main to curb stop (Ft) 21.2 Distance from curb stop to meter (ft) 11 Distance from curb face to curb stop (ft) 1.5 Depth of service (ft) 4.3 Total length of new pipeinstalled (ft) 21.2 Curb stop replaced: Yes size 1" Corporation replaced: Yes size 1" Ball valve replaced: No size 3/4" Remarks: 1-3/4 union installed 1LF outside curb stop				