

186 County St

APPLICATION No.: 4812

TAP CLEARED

LOCATION: _____

DATE

BEF.

AFT.

REMARKS

OWNER: _____

31-313

MEASURES:

Sept 30, 1884

S from Thompson St 17.8'

W from E line County St 4.0'

7-9-75 reamed

1" COPPER SERVICE

11-2-2018: Lead service line replacement program

phase 1, Contractor: P. Gioioso & sons

TYPE CU, Diameter 1 inch, Water Pressure 100

Distance from main to curb stop 24'

Distance curb stop to meter 15'

Distance from curb face to curb stop 1.2'

Depth of service 4.0'

Total length of new pipe installed 15'

Curb stop replaced: NO size 3/4"

Corporation replaced: NO Size 3/4"

Ball valve furnished: YES Size 1"

Remarks: 1- 3/4" union installed 1LF outside curb stop

METER HISTORY

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST | | | REMARKS |
|------|---------|------|------|--------|---------|------|--|--|---------|
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

CHARGE OUTS

