

APPLICATION No.: 4875

TAP CLEARED ✓

LOCATION: 6 Onaka Lane

OWNER: Stella Kraka

MEASURES:

5/8"

N from	Coffin Ave.	120.0 ft.
W from W line	House	4.4 ft.
S from N line	House	2.2 ft.

May 19, 1953 Renewed 1 ft. inside curb stop to inside cellar.
(Note: Curb stop is near property line)
6 ft. of 3/4" copper tubing (Stock supplied & installed by
owner's plumber.)

2/1/08 - Renewed service from main to property line
17 ft - 3/4" copper tubing; 1 - 3/4" curb stop; 1 Caldwell
stop box; 1 - 5/8" x 3/4" lead to cop adapt xxs; 1 - 5/8" x
3/4" Fig. 413. Tap reamed. Foreman: Frank Bento

DATE

BEF.

AFT.

REMARKS

1/24/08 8:00 Dig Safe #

2008-0303220

2/1/08

Tap reamed

[illegible]

CHARGE OUTS

[illegible]