

APPLICATION No.: 4906

## TAP CLEARED

LOCATION: 7 Margin St.OWNER: Manuel S. BaraoMEASURES: 1/2" H lead Dec.11,1884N from Brock Ave. 51.4 ft.E from W line Margin St. 6.6 ft.N from S line House 2.6 ft.

Aug. 18, 1989 Renewed from newly installed 6" ductile main to a point

1 ft. Brito Const. supplied all stock

1 ft. - 3/4" copper tubing 1 - 3/4" corp. tap

1 - 5/8" x 3/4" lead to copper adapt XXS

1" Copper Service

01/11/2019 Lead Service Replacement Program

Phase 1, Contractor P Gioioso &amp; Son

Type CU, Diameter 1in, Water pressure 100

Distance from main to curb stop (ft) N/A

Distance from curb stop to meter (ft) 14

Distance from curb face to curb stop (ft) 1.5

Depth of service (ft) 4.5

Total length of new pipe installed (ft) 14

Curb stop replaced: No, Corporation replaced: NO

Ball valve replaced: Yes size 1"

# METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
2-20-58		5/8	Hersey F	637109					

## CHARGE OUTS

