

APPLICATION No.: 4911

## TAP CLEARED

LOCATION: 105-7-~~9~~ County St.OWNER: Januarria Rogers

| MEASURES:     |            |                          |  |
|---------------|------------|--------------------------|--|
| 3/4"          | Copper     | Dec. 31, 1884            |  |
| N from        | Delano St. | <del>24.7</del> ft. 25.0 |  |
| E from W line | County St. | <del>7.2</del> ft. 3.2   |  |
| N from S line | house      | <del>10.8</del> ft. 10.8 |  |
| E from E line | bldg.      | 3.2                      |  |

March 11, 1957 Renewed from the  $\frac{1}{2}$  tap in main to meter inside cellar

18 f. of 3/4" copper tubing type K, soft

1- 3/4" cop. to cop stop, fig 415

3/4" cop. to I. F. cplg. fig 413

1" x  $\frac{1}{2}$  brass reducing bushing

Fraser, F.

May 23, 1975 Cut in a new 3/4" Curb stop to move the stop closer to the bldg.

4 ft. - 3/4" Copper tubing      3/4" Curb stop  
Caldwell Stop box

*owner complaining of water in curb  
No Leak checked out by Hunt 6/12/90*

[illegible]

## CHARGE OUTS

[illegible]



APPLICATION No.: 25089

## TAP CLEARED

LOCATION: 105 County St.OWNER: Januaria Rogers

MEASURES: 2" Copper Mar. 11, 1957  
1-2" Gate Valve, Dar., 1 R-11/4 Caldwell valve box  
N from N line Mosher St. 60.0 ft.

E from W line County St. 7.5 ft.

N from S line bldg. 17.0 ft.

May 23, 1975 Due to the widening of County St. - the  
2" Gate Box will be located in the street - Replaced  
the gate box with a #10 Gate Box.  
#10 Gate Box, complete  
- - -

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]