

LOCATION: 29 Acushnet Avenue

OWNER: Antone Costa

MEASURES:	1/2"	H. lead	July 28, 1885
	N from	Delano	138.2 ft.
	E from W line	Acush. Av.	6.5 ft.
	N from S line	house	9.3 ft.

April 20, 1976 Renewed from 6" outside curb stop to property line.

5½ ft. - 3/4" Copper tubing 3/4" Curb Stop
2 - 5/8"x 3/4" lead to copper adaptor XS
Caldwell Stop Box

1998 1999 2000

8-26-99 DW White renewed from main to property line.
Stock: 16 ft. - 3/4" Copper tubing, 1 - 3/4" Curb Stop,
1 - Caldwell Stop Box, 1 - 5/8"x3/4" lead to cop. adapt.
XS, 1 - 6"x3/4" Service Saddle DW White to maintain cut.

5/15/2019: Lead service line replacement program Phase 1
Contractor: P.Gioioso & Sons
Type: CU, Diameter 1" Water Pressure 100

Li
Distance curb stop to meter 16'
Distance from curb, face to curb stop 1.5'
Depth of service 4'
Total length of new pipe installed 16'

Cur 1 stop replaced NO
Corporation Replaced NO
Ball valve furnished yes size 1"

Distance from main to curb stop (ft) : N/A

METER HISTORY

CHARGE OUTS

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS
7-15-59	5/8		Calmet	1662029					

