

APPLICATION No.: 5114

TAP CLEARED

LOCATION: 70 Rockland St

OWNER:

31-313

MEASURES: Oct 8, 1885
E X Hall St 74.1 ft
N X S Line Rockland St 7.2 ft
W X E Line House 1.4 ft
11/20/2018 Lead Service Replacement Program
Phase 1, Contractor P Gioioso & Son
Type CU, Diameter 1in, Water pressure 95
Distance from main to curbstop (ft) 7.6
Distance from curb stop to meter (ft) 14.5
Distance from curb face to curb stop (ft) 2
Depth of service (ft) 3.3
Total length of new pipe installed (ft) 7.6
Curb stop replaced: Yes size 1"
Corporation replaced: Yes size 1"
Ball valve replaced: No size 3/4"
Remarks: 1-3/4" union installed 1 LF outside
curb stop

DATE

BEF.

AFT.

REMARKS

METER HISTORY

DATE	SET OUT	SIZE	MAKE	NUMBER	READING	TEST			REMARKS

CHARGE OUTS

