| APPLICATION No.: | 5162 | | TAP CLEARED | | | ✓ |
|---|---|---|---|---|---|---|
| | | DATE | BEF. | AFT. | REMARKS | |

LOCATION: __406 So. Front St.__

OWNER: __John & Hortense C. Martins__

| | | | | | DATE | BEF. | AFT. | REMARKS |
|---|---|---|---|---|---|---|---|---|
| MEASURES: | 3/4" | Copper | July 11,1892 | | | | | |
| | N from | Blackmer St. | ~~136.3~~ ft. | 138.0 ft. | 9-27&28-60 | | | Reamed |
| | W from E line | Front St. | ~~6.7 ft.~~ | 6.0 ft. | | | | |
| | N from S line | house | ~~6.9 ft.~~ | 7.0 ft. | | | | |

W from W line  house            12.3 ft.
-----     main to prop. line          44.0 ft.
Sept. 27 & 28, 1960   Renewed from the main to 3 ft. inside
the curb stop.
23 ft. 3/4" copper tubing       1 3/4" cop. to cop. stop
1 lb. wiping solder       1 5/8" reused corporation cplg.
-----
July 1, 1965   Renewed from a point 5 ft. inside the curb stop
to meter inside the building.
11 ft. 3/4" copper tubing       1 3/4" cop. to cop. cplg. A-1525
-----

J.F Kennedy Hwy. Proj.
June 22, 1983  Renewed from the main to the curb stop.
39.5 ft.-3/4" copper tubing       1-3/4" tap
1-3/4" curb stop             1-Caldwell stop box
- - - -

## METER HISTORY

| DATE | SET OUT | SIZE | MAKE | NUMBER | READING | TEST | | | REMARKS |
|------|---------|------|------|--------|---------|------|--|--|---------|
| 4-8-68 | | 3/4 | Rockwell Mg. | 9804 | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

## CHARGE OUTS